



**DeKalb County Department of Purchasing and Contracting
Office of the Director**

October 23, 2014

TO: All Bidders under Invitation to Bid (ITB) 14-100389
FROM: Department of Purchasing and Contracting, DeKalb County, Georgia

ADDENDUM NO. 1

ITB No. 14-100389 – Chamblee-Dunwoody Streetscapes Phase 2 - PI 0002799, is hereby amended as follows:

1. The following listed questions and answers are provided for your information:

a. **Question:** What makes up the lighting system?

Answer: The lighting system pay item number (682-9030) includes the lighting distribution equipment as specified on specification sheets 25-05 and 25-06 included in the bid documents.

b. **Question:** What is in the lighting system?

Answer: See answer to question "a".

c. **Question:** Please clarify WHERE the DIP waterline is to be moved. It is not obvious on the plans.

Answer: The waterline and service line quantities will be as directed by the Engineer. DeKalb County Department of Watershed Management has requested these quantities to be included for potential conflicts with storm drain or other construction activities.

d. **Question:** What is the purpose of:

615-1200	DIRECTIONAL BORE, 4"	LF	910	\$	-
----------	----------------------	----	-----	----	---

What work is this associated with? Please clarify

Answer: The boring referred above is associated with the lighting conduit. Refer to the Special Provision 615 included in the bid documents for additional information.

e. **Question:** In the pre bid meeting a reference was made to a two year maintenance plan for the landscaping to be installed. We cannot find a section in the specs that clearly define the requirements of the 2 year maintenance plan. Can you please provide the specs for this item or direct us to where in the existing plans and specs that this item may be found.

Addendum No. 1 to ITB 14-100389
Chamblee-Dunwoody Streetscapes Phase 2 - PI 0002799
SMC:YB:kc

yb

Answer: Refer to Sections 702 and 702.5 in the GDOT specifications. This project shall adhere to the GDOT *STANDARD SPECIFICATIONS FOR THE CONSTRUCTION OF TRANSPORTATION SYSTEMS* dated April 18, 2013 as well as any Supplemental and/or Special Provisions provided by the GDOT that concern landscaping as stated on TS-1 in Exhibit 3. These documents reference planting seasons as opposed to a specific time period. There is no project specific special provision for maintenance of landscaping.

f. **Question:** Why does the item Class A Concrete appear in the item list twice?


500-3101	CLASS A CONCRETE	CY	64	\$	-
----------	------------------	----	----	----	---

500-1301	CLASS A CONCRETE	CY	15	\$	-
----------	------------------	----	----	----	---

Answer: This item is listed twice due to the roadway construction (64 CY) and the watershed (15 CY) items. Both line items are required and should be included separately as shown in the bid proposal form.

2. It is the responsibility of each bidder to ensure that he is aware of all addenda issued under this ITB. Please sign and return this addendum. You may call Kimberly Chambers, Contract Administrator at 404-371-3641 before the bids are due to confirm the number of addenda issued.
3. All other conditions remain in full force and effect.

Sincerely,



Scott M. Callan, CPSM
Acting Chief Procurement Officer
Department of Purchasing and Contracting

ACKNOWLEDGMENT

Date _____

The Above Addendum is hereby acknowledged:

(NAME OF BIDDER)

(Signature)

(Title)